



- NOTES:
- 1- THE TRAYER CAT.# 901A LIQUID LEVEL GAUGE IS A COMPLETELY STATIC DEVICE THAT ACTUALLY READS "LOW OIL" IF THE OIL DROPS BELOW PROPER LEVEL. IT IS AVAILABLE TO ALL SWITCH AND TRANSFORMER MANUFACTURERS IN ORDER TO PROMOTE INDUSTRY STANDARDIZATION.
 - 2- DECAL READS:
 "BREAKER TRIPPED WHEN YELLOW INDICATOR PROJECTS IN TO THE SIGHT GLASS. TO RESET BREAKER, OPEN AND CLOSE OPERATING HANDLE"
 - 3- DECAL READS:
 "POTENTIAL TRANSFORMER DISCONNECT SWITCH MUST BE IN OPEN POSITION WHEN DOING HIGH POTENTIAL TESTING."
 - 4- VISIBLE DISCONNECT AND LOAD INTERRUPTER ARE INTERLOCKED SO THAT LOAD INTERRUPTER MUST BE OPEN BEFORE VISIBLE DISCONNECT CAN BE OPERATED
 - 5- DECAL READS:
 LIQUID LEVEL INDICATOR READS "LOW OIL" WHEN OIL IS LOW.
 - 6- DECAL READS:
 FILLED WITH NON PCB MINERAL OIL [LESS THAN 1 PPM] AT TIME OF MANUFACTURE
 - 7- MATERIAL:
 OIL TANK : 7 GA. STAINLESS STEEL
 CABINET : 11GA. STAINLESS STEEL
 LIFT UP TOP : 14 GA. STAINLESS STEEL
 - 8- WEIGHT: 5905 LBS

TRAYER S.O.

FINISH LIGHT GRAY	TRAYER ENGINEERING CORPORATION
MATL. SEE NOTE# 7	898 PENNSYLVANIA AVENUE SAN FRANCISCO, CALIFORNIA 94107 (415) 285-7770
SCALE 1/8" = 1"	SCADA - TEC
DR. BY R.KOWDLEY	15 KV LIQUID INSULATED PADMOUNTED WITH VACUUM FAULT INTERRUPTER WITH VISIBLE DISCONNECTS
CK. BY BQB	CAT# 3805D10VD1M100-211-4-SP5
APPVD. BQB	DRAWING NUMBER 100624
DATE 06-25-10	REVISION A
UNIT TYPE PADMOUNT	