



NOTE:

1- THE TRAYER CAT. 901A LIQUID LEVEL GAUGE IS REMOVABLE FROM THE COMBINATION OIL FILLING - OIL DRAIN - OIL SAMPLING - PORT WHEN THE STAINLESS STEEL METER SEAL IS CUT. THIS IS A COMPLETELY STATIC DEVICE THAT ACTUALLY READS "LOW OIL" IF THE OIL DROPS BELOW PROPER LEVEL. IT IS AVAILABLE TO ALL SWITCH AND TRANSFORMER MANUFACTURERS IN ORDER TO PROMOTE INDUSTRY STANDARDIZATION.

2- ALL GROUNDING NUTS TO BE 1/2-13 STAINLESS STEEL.

3- DECAL READS:

FILLED WITH NON PCB MINERAL OIL [LESS THAN 1 PPM] AT TIME OF MANUFACTURE

4- DECAL READS:

WARNING WHEN SWITCH SIDE MOUNTED (BUSHINGS NOT ON TOP) LIQUID LEVEL GAUGE MUST BE NEAR TOP FOR OIL TO COVER BUSHINGS.

TRAYER S.O.

CATALOG LETTER INSERT	BUSHING AMPERE			FINISH	MATERIAL	SCALE
	L	T	R			
A	200	200	200	NATURAL	# 304 STN. STL.	1/4" = 1"
B	600	200	600			
C	600	600	600			
D	600	200	200			

DR. BY S. I. DAZA
 CK. BY BJB
 APPVD. BJB
 DATE 04-09-02
 UNIT TYPE SUBMERSIBLE

TOLERANCES ± 1/8"

TRAYER ENGINEERING CORPORATION 898 PENNSYLVANIA AVENUE SAN FRANCISCO, CALIFORNIA 94107 (415) 285-7770	
15 KV VACUUM SWITCH WITH TRI PHASE VISIBLE DISCONNECT TRAYER CAT.#102S2__M1	
DRAWING NUMBER 020409	REVISION C 06-06-05